

Dane do obliczeń : pora nocna

Źródła punktowe

Nr	X[m]	Y[m]	z[m]	Pma	Symbol
1	349.5	228.0	5.0	80.0	wentylator
2	349.9	231.5	5.0	80.0	wentylator
3	350.5	239.2	5.0	80.0	wentylator
4	350.6	243.3	5.0	80.0	wentylator
5	358.6	254.1	5.0	80.0	wentylator
6	359.0	258.1	5.0	80.0	wentylator
7	359.3	265.7	5.0	80.0	wentylator
8	359.7	269.4	5.0	80.0	wentylator
9	236.0	242.5	7.0	82.0	wentylator
10	249.9	242.0	7.0	82.0	wentylator
11	264.2	240.8	7.0	82.0	wentylator
12	277.0	240.3	7.0	82.0	wentylator
13	293.4	238.7	7.0	82.0	wentylator
14	305.5	238.2	7.0	82.0	wentylator
15	318.5	237.7	7.0	70.0	wentylator
16	335.0	236.7	7.0	70.0	wentylator
17	244.0	269.6	7.0	82.0	wentylator
18	255.5	269.1	7.0	82.0	wentylator
19	271.5	268.2	7.0	82.0	wentylator
20	285.0	267.4	7.0	82.0	wentylator
21	300.5	266.2	7.0	82.0	wentylator
22	313.2	265.2	7.0	82.0	wentylator
23	327.6	263.9	7.0	70.0	wentylator
24	341.8	263.1	7.0	70.0	wentylator
25	259.4	305.8	5.0	82.0	wentylator
26	288.2	303.6	5.0	82.0	wentylator
27	259.0	298.0	5.0	82.0	wentylator
28	287.9	296.7	5.0	82.0	wentylator
29	320.8	302.4	5.0	70.0	wentylator
30	348.4	300.0	5.0	70.0	wentylator
31	320.8	295.1	5.0	70.0	wentylator
32	348.2	293.6	5.0	70.0	wentylator
33	280.0	224.6	1.0	92.0	agregat
34	292.3	224.0	1.0	92.0	agregat

Ekrany akustyczne :

WSPÓŁRZĘDNE WIERZCHOŁKÓW :

Nr	X1[m]	Y1[m]	X2[m]	Y2[m]	X3[m]	Y3[m]	X4[m]	Y4[m]	h0[m]	h[m]
1	313.0	340.4	368.9	337.0	367.9	320.9	312.4	324.1	0.0	6.4
2	243.0	313.7	367.1	306.0	366.3	286.3	241.7	294.3	0.0	3.3
3	235.0	279.9	358.3	271.6	357.2	252.2	233.5	260.6	0.0	4.7
4	226.2	253.7	349.7	245.5	348.6	226.2	224.9	234.5	0.0	4.7

WSPÓŁCZYNNIKI ODBICIA DLA ŚCIAN

Nr	ściana 1	ściana 2	ściana 3	ściana 4	dach

1	1.0000	1.0000	1.0000	1.0000	1.0000
2	1.0000	1.0000	1.0000	1.0000	1.0000
3	1.0000	1.0000	1.0000	1.0000	1.0000
4	1.0000	1.0000	1.0000	1.0000	1.0000

=====